WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93119
Permit No.
Basin 27
NOTICE OF INTENT NO. 84802

MCF-04

1. OWNER Basin Remediation
MAILING ADDRESS 875 Warm Springs Rd
Henderson NV 89015

ADDRESS AT WELL LOCATION Warm Springs Rd & Pabco Rd
Henderson NV

2. LOCATION SE ¼ SW ¼ Sec. 5 T. 22 N/S R. 63 E/W County
PERMIT NO. Issued by Water Resources
179-05-401-001 Parcel No.
BMI Site Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand + Gravel		0	38	38
Silt		38	115	77
Clay		115	119	4
Silt		119	212	93
Sand		212	215	3
Silt		215	330	115
Int Bedded Silt + Sand		330	343	13
Silt		343	384	41
Sand		384	394	10
Silt		394	404	10
Int Bedd Silt + Sand		404	420	16

DCNR/DWR
RECEIVED
MAY 10 2004
LAS VEGAS OFFICE

Date started 2/5, 2004
Date completed 2/9, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 420 Feet Depth Cased 379.5 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 7/8 Inches	0 Feet	420 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4 1/2		Sch 80 PVC	0	399.5

Perforations:
Type perforation Factory Slot
Size perforation .010
From 379 feet to 399 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 370
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 370 feet to 402 feet

9. WATER LEVEL
Static water level 34.51 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells (Contractor)
Address 1421 S 39th Ave (Contractor)
Phoenix, AZ 85009
Nevada contractor's license number issued by the State Contractor's Board 0012852
Nevada driller's ~~license number~~ issued by the Division of Water Resources, the on-site driller M-1747
Signed (By driller performing actual drilling on site or contractor)
Date 2/16/04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627