

OFFICE USE ONLY  
 Log No. 93123  
 Permit No. \_\_\_\_\_  
 Basin. 163

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26385

1. OWNER JOHN + PEGGY ELLENBURG ADDRESS AT WELL LOCATION EMERALD AV. + S. HAWNEE ST.  
 MAILING ADDRESS \_\_\_\_\_ SANDY VALLEY NV.  
 2. LOCATION SE 1/4 SW 1/4 NE 1/4 Sec 22 T. 24 N/S R. 56 E County CLACK  
 PERMIT NO. 200-22-501-014 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED:  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE:  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE:  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	6	6
CLAY		6	32	26
CALICHE		32	39	7
CLAY		39	69	30
CALICHE		69	77	8
CLAY		77	92	15
CALICHE		92	98	6
CLAY		98	108	10
CALICHE	W.B	108	115	7
CLAY		115	132	17
CALICHE	W.B	132	142	10
CLAY + GRAVEL		142	165	23
GRAVEL	W.B	165	170	5

DCNR/DWR  
 RECEIVED  
 MAY 13 2004  
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 170 Feet Depth Cased 170 Feet  
 HOLE DIAMETER (BIT SIZE)  
10 5/8 Inches From 0 Feet To 170 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>4.33</u>	<u>.316</u>	<u>0</u>	<u>170</u>

Perforations:  
 Type perforation SAW CUT  
 Size perforation 8 INCH BY 6 INCH  
 From 170 feet to 130 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 50 FT.  Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 170 feet to 50 feet

Date started 4-12, 2004  
 Date completed 4-16, 2004

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 98 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name BUDGET DRILLING CO Contractor  
 Address P.O. BOX 3505 SANDY VALLEY NV. 89041 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 40020  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date 4-20-2004