

WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

USE ADDITIONAL SHEETS IF NECESSARY
STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 93133
Permit No. _____
Basin 162

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534:170 and NAC 534.340

NOTICE OF INTENT NO. 26357

1. OWNER JON & PATRICIA BRIDENBAKER
MAILING ADDRESS 720 W. GARDEN
PAHRUMP, NV

ADDRESS AT WELL LOCATION 720 W. GARDEN

2. LOCATION NE 1/4 NW 1/4 Sec. 28 T 20
PERMIT NO. 39-083-12
Issued by Water Resources Parcel No.

N/S R 53 E NYE County
CALVADA VALLEY UNIT 8B
Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	14	14
CALICHE		14	25	11
CLAY		25	75	50
CALICHE	WB	75	84	9
CLAY		84	96	12
CALICHE	WB	96	115	19
CLAY		115	130	15
CALICHE	WB	130	145	15
CLAY		145	160	15
CALICHE	WB	160	175	15
CLAY		175	180	5

8. WELL CONSTRUCTION

Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>10</u>	<u>0</u>	<u>160</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>3.63</u>	<u>.250</u>	<u>0</u>	<u>180</u>

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 90 feet to 180 feet
From _____ feet to _____ feet

Surface Seal: Yes No
Depth of Seal 50
Placement Method: Pumped Poured
Seal Type: Neat Cement Cement Grout Concrete Grout
Gravel Packed: Yes No
From 50 feet to 180 feet

9. WATER LEVEL

Static water level 48 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC.
Contractor

Address P.O. BOX 4220
Contractor

PAHRUMP, NV. 89048

Nevada contractor's license number issued by the State Contractor's Board 47333

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2063

Signed Bob Torrey
By driller performing actual drilling on-site or contractor

Date 5/12/04

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR
RECEIVED
MAY 14 2004
LAS VEGAS OFFICE