

WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

USE ADDITIONAL SHEETS IF NECESSARY
STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93137
Permit No. _____
Basin 162

NOTICE OF INTENT NO. 26371

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

1. OWNER **MAGDENBERG**
MAILING ADDRESS 3301 E. MCGRAW
PAHRUMP, NV
ADDRESS AT WELL LOCATION 3301 E. MCGRAW
2. LOCATION SE 1/4 NW 1/4 Sec. 19 T 21 N/S R 54 E NYE County
PERMIT NO. 45-264-07 Parcel No. GREEN SADDLE RANCHES Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	15	15
CALICHE		15	22	7
CLAY		22	75	53
CALICHE	WB	75	78	3
CLAY		78	110	32
CALICHE	WB	110	123	13
CLAY		123	145	22
CALICHE	WB	145	155	10
CLAY		155	165	10
CALICHE	WB	165	178	13
CLAY		178	180	2

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet
HOLE DIAMETER (BIT SIZE)
From 0 Feet To 180 Feet
Inches _____ Feet _____
Inches _____ Feet _____
CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	180

Perforations:
Type perforation **SAWCUT**
Size perforation 1/8 X 3
From 100 feet to 180 feet
From _____ feet to _____ feet
Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 180 feet

DCNR/DWR
RECEIVED
MAY 14 2004
LAS VEGAS OFFICE

Date started 5/5/2004 .19
Date completed 5/11/2004 .19

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
Address P.O. BOX 4220 Contractor
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2063
Signed Don Touhy
By driller performing actual drilling on-site or contractor
Date 5/12/2004