USE ADDITIONAL SHEETS IF NECESSARY

WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93139
Permit No.
Basin 162

NOTICE OF INTENT NO. 26368

1. OWNER KENZEUICK
MAILING ADDRESS 2650 RIVER PLATE
PAHRUMP, NV

ADDRESS AT WELL LOCATION 2650 RIVER PLATE

2. LOCATION NE 1/4 SE 1/4 Sec. 29 T 20 N/S R 53 E NYE County
PERMIT NO. (Issued by Water Resources) 40-252-16 (Parcel No.) CALVADA VALLEY UNIT 5 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
EXISTING		0	140	140
CLAY		140	145	5
CALICHE	WB	145	158	13
CLAY		158	180	22
CALICHE	WB	180	188	8
CLAY		188	205	17
CALICHE	WB	205	215	10
CLAY		215	223	8
CALICHE	WB	223	235	12
CLAY		235	240	5

DCNR/DWR
RECEIVED
MAY 17 2004
LAS VEGAS OFFICE

Date started 5/11/2004, 19__
Date completed 5/11/2004, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
EXISITING	Inches	0	Feet	140	Feet
6	Inches	140	Feet	240	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
EXISTING			0	140
4	2.06	.236	0	240

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3

From 120 feet to 130 feet
From 140 feet to 150 feet
From 160 feet to 170 feet
From 180 feet to 190 feet
From 200 feet to 210 feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal EXISTING
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 240 feet

9. WATER LEVEL
Static water level 74 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address P.O. BOX 4220 (Contractor)
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on-site or contractor)
Date 5/13/04