

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 93183  
 Permit No. \_\_\_\_\_  
 Basin 162  
 NOTICE OF INTENT NO. 26539

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Spalding Construction  
 MAILING ADDRESS \_\_\_\_\_  
 ADDRESS AT WELL LOCATION 3581 S. Ranger Way

2. LOCATION NE 1/4 SW 1/4 Sec 36 T 20-S N R 53 E Nye County  
 PERMIT NO. \_\_\_\_\_ 41-124-03 CV - Ut:2 Bk:36 Lt:14  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Brown Clay		4	16	12
Limestone		16	19	3
Brown Clay		19	24	5
Limestone		24	27	3
Brown Clay		27	32	5
Limestone		32	36	4
Brown Clay/Caliche		36	57	21
Limestone		57	64	7
Brown Clay/Caliche	X	64	160	96

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
12 Inches 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	160

Perforations:  
 Type perforation Torch Cut  
 Size perforation 1/4" width 8" long  
 From 120 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 160 feet

9. WATER LEVEL  
 Static water level 64 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name JIM PIKE WELL DRILLING, LLC.  
 (CONTRACTOR)

Address P.O. BOX 56  
 (CONTRACTOR)  
PAHRUMP, NV. 89041  
 Nevada contractor's license number issued by the State Contractor's Board 17563A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1324  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date May 24, 2004

Date started May 17, 20 04  
 Date completed May 17, 20 04

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>4</u>	<u>1/4</u>

DGNN/DWR  
 RECEIVED  
 MAY 25 2004

LAS VEGAS OFFICE