WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93191
Permit No.
Basin 212

NOTICE OF INTENT NO. 25671

MW-3

1. **OWNER** Catholic Charities of Southern Nevada
MAILING ADDRESS PO Box 1926
Las Vegas NV 89125

ADDRESS AT WELL LOCATION 1501 Las Vegas Blvd
Las Vegas NV 89101

2. **LOCATION** NE 1/4 NE 1/4 Sec 27 T 20S N/S R 61 E Clark County

PERMIT NO (Issued by Water Resources) 139-27-503-002 (Parcel No.) (Subdivision Name)

3. **WORK PERFORMED**
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. **PROPOSED USE**
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. **WELL TYPE**
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
The well casing was pulled from the well. The depth of the well after pulling the casing was approximately 15 feet because of collapse of some of the gravel pack. Neat cement was settled into the bottom of the hole using a weight fixed to the end of a surveyors' tape; the hole was filled to the surface with neat cement.				

NEVADA DIVISION OF WATER RESOURCES
RECEIVED
MAY 2 0 2004
LAS VEGAS OFFICE

Date started March 29, 2004
Date completed March 29, 2004

7. **WELL TEST DATA**
TEST METHOD ☐ Bailer ☐ Pumped ☐ Air Lift

G.P.M	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRTUCTION**
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
5 1/2	Inches	0	Feet	30	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375		0.308	0	30

Perforations:
Type perforation Factory slot PVC
Size perforation 0.020 inch
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 2 feet
Placement Method ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 2 feet to 30 feet

9. **WATER LEVEL**
Static water level 18 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. **DRILLER'S CERTIFICATE**
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Converse Consultants (Contractor)
Address 731 Pilot Road, Ste. H, Las Vegas NV 89119 (Contractor)
Nevada contractor's license number
Issued by the State Contractor's Board 48947
Nevada driller's license number issued by the
Division of Water Resources, the on-site driller M 1589
Signed (By driller performing actual drilling on-site or contractor)
Date 5/28/04

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (0)-627