

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25671

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

MW-5 (Located in center of site)

1. **OWNER** Catholic Charities of Southern Nevada **ADDRESS AT WELL LOCATION** 1501 Las Vegas Blvd
MAILING ADDRESS PO Box 1926 Las Vegas NV 89101
Las Vegas NV 89125

2. **LOCATION** NE 1/4 NE 1/4 Sec 27 T 20S N/S R 61 E Clark County
PERMIT NO 139-27-503-002
Issued by Water Resources Parcel No. Subdivision Name

3. **WORK PERFORMED** New Well Replace Recondition Deepen Abandon Other _____

4. **PROPOSED USE** Domestic Municipal/Industrial Irrigation Monitor Test Stock

5. **WELL TYPE** Cable Rotary RVC Air Other _____

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Waiver No R-1233				
Casing left in hole. Neat cement was funneled into the casing using a weighted tape to insure that cement did not bridge. Casing was filled to the surface with neat cement.				
DONFLOWER RECEIVED MAY 11 2004 LAS VEGAS OFFICE				

8. **WELL CONSTRUCTION**

Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>5 1/2</u> Inches	<u>0</u> Feet <u>30</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>		<u>0.308</u>	<u>0</u>	<u>30</u>

Perforations:

Type perforation Factory slot PVC
 Size perforation 0.020"

From 10 feet to 30 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 2 1/2 ft Cement Grout
 Placement Method Pumped Poured Concrete Grout
 Gravel Packed: Yes No

From 5 feet to 30 feet

9. **WATER LEVEL**

Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started May 3, 2004
 Date completed May 3, 2004

7. **WELL TEST DATA**

TEST METHOD	<input type="checkbox"/> Bailer <input type="checkbox"/> Pumped <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. **DRILLER'S CERTIFICATE**

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Converse Consultants Contractor
 Address 731 Pilot Road, Ste. H, Las Vegas NV 89119 Contractor

Nevada contractor's license number 48947
 Issued by the State Contractor's Board
 Nevada driller's license number issued by the M 1589
 Division of Water Resources, the on-site driller

Signed [Signature]
 By driller performing actual drilling on-site or contractor

Date 5/28/04