

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 93195  
 Permit No. \_\_\_\_\_  
 Basin. 212

PRINT OR TYPE ONLY  
 NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 25671

MW-7 (Located near old guard shack, southeast quadrant of site)

1. **OWNER** Catholic Charities of Southern Nevada **ADDRESS AT WELL LOCATION** 1501 Las Vegas Blvd  
**MAILING ADDRESS** PO Box 1926 Las Vegas NV 89101

2. **LOCATION** NE 1/4 NE 1/4 Sec 27 T 20S N/S R 61 E Clark County  
**PERMIT NO** 139-27-503-002  
Issued by Water Resources Parcel No. Subdivision Name

3. **WORK PERFORMED**  New Well  Replace  Recondition  Decpen  Abandon  Other \_\_\_\_\_

4. **PROPOSED USE**  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock

5. **WELL TYPE**  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thick-ness
<b>Waiver No. R-1233</b>				
Casing left in hole. Neat cement funneled into hole using weighted tape to make sure cement filled from the bottom of the casing (didn't bridge). Casing filled to the face with neat cement.				
DOWNHOLE RECEIVED MAY 2 6 2004 LAS VEGAS OFFICE				

8. **WELL CONSTRUCTION**

Depth Drilled 30 Feet Depth Cased 30 Feet

**HOLE DIAMETER (BIT SIZE)**

Inches	From	Feet	To	Feet
<u>5 1/2</u>	<u>0</u>	<u>30</u>	<u>30</u>	<u>30</u>

**CASING SCHEDULE**

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>		<u>0.308</u>	<u>0</u>	<u>30</u>

**Perforations:**

Type perforation Factory slot PVC  
 Size perforation 0.020"

From 10 feet to 30 feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout

Depth of Seal \_\_\_\_\_

Placement Method  Pumped  Poured

Gravel Packed:  Yes  No

9. **WATER LEVEL**

Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started May 3, 2004  
 Date completed May 3, 2004

7. **WELL TEST DATA**

TEST METHOD	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pumped <input type="checkbox"/> Air Lift			

10. **DRILLER'S CERTIFICATE**

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Converse Consultants Contractor  
 Address 731 Pilot Road, Ste. H, Las Vegas NV 89119 Contractor

Nevada contractor's license number 48947  
 Issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1589

Signed Donald J. [Signature]  
 By driller performing actual drilling on-site or contractor

Date 5/28/04