


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 93217  
 Permit No. 48752  
 Basin 105



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51042

OWNER Gardnerville Ranchose GID ADDRESS AT WELL LOCATION Well #2A  
 MAILING ADDRESS 931 Mitch Drive  
Gardnerville, NV 89410

2. LOCATION SW 1/4 SE 1/4 Sec. 10 T 12N N/S R 20E E Douglas County  
 PERMIT NO. 48752 1220-10-811-014  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
sand/cobbles w/s clay		0	40	
sand & gravel w/cobbles		40	128	88
sand & gravel w/clay		128		
stringers			151	23
br. clay w/sand		151	170	19
sand/gravel w/cobbles		170	296	126
tan clay w/sand, gravel & cobbles		296		
tan clay w/s sand		303	309	6
sand & gravel w/tan clay		309	320	11
clay w/sm. gravel & sand		320	325	5
sand & gravel w/cobbles		325	350	25
clay w/sand & gravel		350	375	25
gravel & coarse sand		375	381	6
hd. rock w/sand & gravel		381	406	25
clay		406		
w/sand, gravel, cobbles			414	8
sand/gravel/cobbles		414		
w/clay stringers			463	49
sand/gravel/clay w/s cobbles		463		
sand/gravel/cobbles w/s			472	9
clay			491	19
hd. rock, sand & gravel		491	562	71

Continued on next page

Date started 4/2/04, 19\_\_\_\_  
 Date completed 4/26/04, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
P/L 179.23	1800	144.30	91.5 hrs

8. WELL CONSTRUCTION  
 Depth Drilled 696 Feet Depth Cased 670 Feet

HOLE DIAMETER (BIT SIZE)

From	To
36 Inches	40 Feet
24 Inches	696 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
30		.375	0	40
16		.312	+2	270
16		.312	340	360

continued pg 2

Perforations:  
 Type perforation wire wrap  
 Size perforation .100 slot

From	feet to	feet
270	340	feet
360	440	feet
460	530	feet
550	650	feet
feet to	feet	feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Placement Method:  Pumped  
 Poured

Gravel Packed:  Yes  No  
 From 115 feet to 696 feet

9. WATER LEVEL  
 Static water level 34.90 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. Contractor  
 Address 4675 W. Winnemucca Blvd Contractor  
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 56797  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2177

Signed [Signature]  
 By driller performing actual drilling on-site or contractor

Date 4/30/04

