

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **25676**

1. OWNER Virgin Valley Water Dist ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 500 RIVERSIDE RD
MESQUITE NEV 89027
 2. LOCATION N/E 1/4 N/E 1/4 Sec 7 T 14S N/S R 70 E CLARK County
 PERMIT NO. _____ Issued by Water Resources Parcel No. 03400001010 Subdivision Name MO

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. WWD LBS LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>FINE SAND & GRAVEL</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>SILTY CLAYEY MED SAND</u>		<u>10</u>	<u>21</u>	<u>11</u>
<u>MED SAND & GRAVEL</u>		<u>21</u>	<u>43</u>	<u>22</u>
<u>COURSE SAND & GRAVEL</u>		<u>43</u>	<u>54</u>	<u>11</u>
<u>COURSE SAND & COBBLES</u>		<u>54</u>	<u>75</u>	<u>21</u>
<u>COURSE SAND & GRAVEL</u>		<u>75</u>	<u>78</u>	<u>3</u>

GPS (N 36° 43.972
W 119° 13.309

8. WELL CONSTRUCTION
 Depth Drilled 78 Feet Depth Cased 75 Feet
 HOLE DIAMETER (BIT SIZE)
1 7/8 Inches From 0 Feet To 20 Feet
9 7/8 Inches From 20 Feet To 78 Feet
 _____ Inches From _____ Feet To _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 3/4</u>		<u>3/8</u>	<u>0</u>	<u>20</u>
<u>3</u>		<u>SCHED 40</u>	<u>0</u>	<u>35</u>

Perforations:
 Type perforation 5/16" PVC
 Size perforation 10" 10
 From 35 feet to 75 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 30 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 78 feet to 30 feet

9. WATER LEVEL
 Static water level 11.2 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name LAYNE CHRISTENSEN CO Contractor
 Address 11001 ETIWANDA AV Contractor
FONTANA CA 92337
 Nevada contractor's license number issued by the State Contractor's Board 0019101
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1682
 Signed [Signature]
 Date 5-19-04

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>5-7</u>		<u>8 hrs</u>