WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93238
Permit No. 24440
Basin 87

NOTICE OF INTENT NO. 51683

1. OWNER Daniel & Elli Dreouen
MAILING ADDRESS 2090 Roweanna St.
Las Vegas, NV 89117

ADDRESS AT WELL LOCATION 3773 Baker Lane, Reno, NV

2. LOCATION NE 1/4 NW 1/4 Sec. 25 T 19N N/S R 19E E Washoe County
PERMIT NO. 24440, R-470 Waiver (Issued by Water Resources) | 024-033-11 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned the well by removing the pump, cutting the casing down approximately 12" and digging to a depth of about 2' and 6" around the casing. We then filled the well with neat cement mixed 5.2 gallons/sack and pumped using tremie pipe from the bottom to top. We allowed the top to "Mushroom" at the top of the abandoned well. We pumped approximately 1.5 cu. yards of neat cement.				
Washoe Co. Permit # WL040102				

RECEIVED
04 MAY 17 PM 1:09
STATE ENGINEERS OFFICE

Date started 5/14/2004, 19__
Date completed 5/14/2004, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 71 Feet Depth Cased 71 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.250	0	71

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 71
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 33 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2159
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 5/14/04

USE ADDITIONAL SHEETS IF NECESSARY