WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93241
Permit No.
Basin 212

NOTICE OF INTENT NO. 24844

1. OWNER Henry Gomes
MAILING ADDRESS 3282 Ruledge dr. Las vegas, NV 89120
ADDRESS AT WELL LOCATION 5980 Spring Mountain rd. Las vegas, NV

2. LOCATION NW ¼ NW ¼ Sec. 13 T. 21 N/S R. 60 E. Clark County
PERMIT NO. Issued by Water Resources
Parcel No. 163-13-101-007
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphault		0	6"	.5
Backfill		6"	1.5	1
Clayey silt w/sand		1.5	21	19.5
Caliche		21	22	1
Clayey w/sand		22	24	2
Fine to coarse sand		24	35	6
Silty clay w/coarse gravel		35	75	40
silty clay w/sand		75	100	25
	808			

DCNR/DWR
RECEIVED
MAY 26 2004
LAS VEGAS OFFICE

Date started May 21, 2004
Date completed May 21, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	100 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PVC	Sch 40	0	100

Perforations:
Type perforation Factory slot
Size perforation .020
From 70 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 65 to 60 Bentonite
Placement Method: ☐ Pumped ☐ Poured 60 to 0' neat cement
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 65 feet to 100 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elite Drilling Inc. Contractor
Address 5115 S. Industrial rd #104 Contractor
Las vegas, NV 89118
Nevada contractor's license number issued by the State Contractor's Board 0054931
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869
Signed By driller performing actual drilling on site or contractor
Date 5-26-04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627