

Log No. **93243**
 Permit No. **212**
 Basin

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26014

1. OWNER Joe D. Neal ADDRESS AT WELL LOCATION
 MAILING ADDRESS 5695 N. Gilbert Las Vegas, Nev. 89130

2. LOCATION SW 1/4 SW 1/4 Sec 26 T19S N/S R60 E Clark County
 PERMIT NO. 125-26-402-006 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Popcorn Caliche		0	30	
Caliche		30	60	
Popcorn Caliche		60	115	
Caliche & Water	xx	115	130	
Sandy Clay		130	250	
Caliche & Water	xx	250	265	
Clay & Sand		265	365	
Hard Rock		365	385	
Caliche & Water	xx	385	420	
Clay		420	460	
Caliche & Water	xx	460	555	

8. WELL CONSTRUCTION
 Depth Drilled 555 Feet Depth Cased 555 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 1/4 Inches 0 Feet 50 Feet
9 7/8 Inches 50 Feet 555 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	50
6 1/2 PVC SRD			+1	555

Perforations:
 Type perforation Factory
 Size perforation .032 Sieve Type
 From 470 feet to 490 feet
 From 510 feet to 530 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water 103 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.1 °F Quality _____

Date started 04/21/04, 20____
 Date completed 04/27/04, 20____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick Contractor
 Address 5360 N. Bonita Vista St.
Las Vegas, Nevada 89149
 Nevada contractor's license number 10062
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
 Signed VH Dimick
 By Driller performing actual drilling on site or contractor
 Date 04-29-04

DCNR/DWR
 RECEIVED
 MAY 26 2004
 LAS VEGAS OFFICE