WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No 93267
Permit No.
Basin 103

NOTICE OF INTENT NO. 49326

1. OWNER Deanne Stilwell
MAILING ADDRESS 1649 Quail Lane
Carson City, NV 89701

ADDRESS AT WELL LOCATION 1649 Quail Lane

2. LOCATION SE 1/4 NE 1/4 Sec. 23 T 15N N/S R 20E E Carson County
PERMIT NO. R-456 (Issued by Water Resources) 010-094-03 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned a 5 3/4" ID well by diggining down around the outside of the well about 4 feet from surface. We then pumped approximately 2.25 cu. yards of neat cement using tremie pipe from the bottom to the top. The top 2' of casing was removed. This was in accordance with Tim Hunt's proceedure on abandoning this well.				

RECEIVED 03 NOV 25 AM 10:42 STATE ENGINEER'S OFFICE

Date started 11/19/2003, 19__
Date completed 11/19/2003, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 231 Feet Depth Cased 231 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8'	Inches	0	Feet	231	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	8.81	10 gauge	0	231

Perforations:
Type perforation Torch
Size perforation 5" x 1/8"
From 204 feet to 228 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 231
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 183 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 11/19/03

USE ADDITIONAL SHEETS IF NECESSARY