WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

USE ADDITIONAL SHEETS IF NECESSARY
STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93303
Permit No.
Basin 162

NOTICE OF INTENT NO. 24111

1. OWNER BETTY MCEUEN & CLAUDE BRINEGAR
MAILING ADDRESS 3610 QUAIL RUN
PAHRUMP, NV

ADDRESS AT WELL LOCATION 3610 QUAIL RUN

2. LOCATION NE 1/4 NW 1/4 Sec. 36 T 19 N/S R 52 E NYE County
PERMIT NO. (Issued by Water Resources) | Parcel No. 28-231-08 | Subdivision Name BELL VISTA UNIT 2

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SLIT		0	3	3
CLAY		3	15	12
CALICHE		15	21	6
CLAY		21	70	49
CALICHE	WB	70	78	8
CLAY		78	126	48
CALICHE	WB	126	135	9
CLAY		135	150	15
CALICHE	WB	150	165	15
CLAY		165	174	9
CALICHE	WB	174	185	11
CLAY		185	190	5
CALICHE	WB	190	200	10

DCNR/DWR
RECEIVED
JUN 21 2004
LAS VEGAS OFFICE

Date started 6/10/2004 , 19__
Date completed 6/12/2004 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	200

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 120 feet to 160 feet
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address P.O. BOX 4220 (Contractor)
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on-site or contractor)
Date 6/14/04