

USE ADDITIONAL SHEETS IF NECESSARY
 STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 93304
 Permit No. _____
 Basin 162
 NOTICE OF INTENT NO. 26509

PRINT OR TYPE ONLY
 NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER STANLEY & MARIE JANET LUBERA ADDRESS AT WELL LOCATION 5881 E. DOUBLE TREE
 MAILING ADDRESS 5881 E. DOUBLE TREE
PAHRUMP, NV
 2. LOCATION NE 1/4 SE 1/4 Sec. 16 T 21 N/S R 54 E NYE County
 PERMIT NO. 43-101-07 Subdivision Name COTTONWOODS @ HAFEN RANCH
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SILT-LOOSE ROCK		0	5	5
SAND & ROCK		5	15	10
SANDY CLAY ROCK		15	45	30
SANDY CLAY GRAVEL		45	78	33
CEMENTED GRAVEL	WB	78	85	7
SAND & GRAVEL	WB	85	105	20
CEMENTED SAND & GRAVEL	WB	105	110	5
CLAY & SAND		110	145	35
CEMENTED SAND	WB	145	150	5
CLAY		150	170	20
CEMENTED SAND	WB	170	175	5
CLAY		175	180	5

DCNR/DWR
RECEIVED
JUN 2 2004
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	180

Perforations:
 Type perforation SAWCUT
 Size perforation 1/8 X 3
 From 85 feet to 125 feet
 From 145 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 180 feet

9. WATER LEVEL
 Static water level 80 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
 Address P.O. BOX 4220 Contractor
PAHRUMP, NV, 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 6/14/04

Date started 6/8/2004 .19
 Date completed 6/12/2004 .19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			