

USE ADDITIONAL SHEETS IF NECESSARY
 STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 93306
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **26512**

1. OWNER ISIDORA ALCAZAR ADDRESS AT WELL LOCATION 5401 MALIBU
 MAILING ADDRESS 5401 MALIBU
PAHRUMP, NV

2. LOCATION SW 1/4 NW 1/4 Sec. 8 T 21 N/S R 54 E NYE County
 PERMIT NO. _____ Parcel No. 45-113-10 Subdivision Name SUNLAND ESTATES
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SILT		0	4	4
CLAY		4	16	12
CALICHE		16	21	5
CLAY		21	70	49
CALICHE	WB	70	80	10
CLAY		80	105	25
CALICHE	WB	105	118	13
CLAY		118	130	12
CALICHE	WB	130	135	5
CLAY		135	145	10
CALICHE		145	153	8
CLAY		153	160	7

DCNR/DWR
RECEIVED
JUN 21 2004
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	160

Perforations:
 Type perforation SAWCUT
 Size perforation 1/8 X 3

From 100 feet to 160 feet
 _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 61 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC.
 Contractor

Date started 6/11/2004, 19
 Date completed 6/12/2004, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

Address P.O. BOX 4220 Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 6/14/04