

WHITE - DIVISION OF WATER RESOURCES  
CANARY - CLIENT'S COPY  
PINK - WELL DRILLER'S COPY

USE ADDITIONAL SHEETS IF NECESSARY  
STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. **93316**  
Permit No. \_\_\_\_\_  
Basin 162

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **26384**

1. OWNER **RANDY KAMPEN**  
MAILING ADDRESS **1650 E. CAVALRY PAHRUMP, NV**

ADDRESS AT WELL LOCATION **1650 E. CAVALRY**

2. LOCATION **NW 1/4 NE 1/4 Sec. 35 T 20**  
PERMIT NO. **42-701-05**  
Issued by Water Resources Parcel No.

**N/S R 53 E NYE** County  
**CALVADA VALLEY UNIT 3** Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FILL		0	3	3
CLAY		3	15	12
CALICHE		15	25	10
CLAY		25	46	21
CALICHE		46	55	9
CLAY		55	78	23
CALICHE	WB	78	82	4
CLAY		82	108	26
CALICHE	WB	108	116	8
CLAY		116	128	12
CALICHE	WB	128	149	21
CLAY		149	160	11
CALICHE	WB	160	171	11
CLAY		171	185	14
CALICHE	WB	185	200	15

8. WELL CONSTRUCTION

Depth Drilled **200** Feet Depth Cased **200** Feet

HOLE DIAMETER (BIT SIZE)  
From **10** Inches To **0** Feet To **200** Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6</b>	<b>3.63</b>	<b>.250</b>	<b>0</b>	<b>200</b>

Perforations:  
Type perforation **SAWCUT**  
Size perforation **1/8 X 3**  
From **120** feet to **200** feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal **50**  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From **50** feet to **200** feet

9. WATER LEVEL  
Static water level **57** feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.** Contractor  
Address **P.O. BOX 4220** Contractor  
**PAHRUMP, NV. 89048**  
Nevada contractor's license number issued by the State Contractor's Board **47333**  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1426**  
Signed *[Signature]*  
By driller performing actual drilling on-site or contractor  
Date **6/11/04**

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR  
RECEIVED  
JUN 15 2004  
LAS VEGAS OFFICE