

USE ADDITIONAL SHEETS IF NECESSARY
 STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. **93319**
 Permit No. _____
 Basin **162**

PRINT OR TYPE ONLY
 NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **26107**

1. OWNER **MIKE BRADY** ADDRESS AT WELL LOCATION **1051 E. CARSON**
 MAILING ADDRESS **1051 E. CARSON**
PAHRUMP, NV

2. LOCATION **SW 1/4 NW 1/4 Sec. 14 T 21 N/S R 53 E NYE** County
 PERMIT NO. **44-722-12** **MESA OESTE ESTATES UNIT 1**
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|----------|--------------|------|-----|-----------|
| CLAY | | 0 | 15 | 15 |
| CALICHE | | 15 | 23 | 8 |
| CLAY | | 23 | 78 | 55 |
| CALICHE | | 78 | 85 | 7 |
| CLAY | | 85 | 130 | 45 |
| CALICHE | WB | 130 | 146 | 16 |
| CLAY | | 146 | 165 | 19 |
| CALICHE | WB | 165 | 178 | 13 |
| CLAY | | 178 | 186 | 8 |
| CALICHE | WB | 186 | 197 | 11 |
| CLAY | | 197 | 210 | 13 |
| CALICHE | WB | 210 | 225 | 15 |
| CLAY | | 225 | 230 | 5 |
| CALICHE | WB | 230 | 240 | 10 |
| CLAY | | 240 | 250 | 10 |

DNRF/DWR
RECEIVED
JUN 15 2004
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled **250** Feet Depth Cased **250** Feet

HOLE DIAMETER (BIT SIZE)
 From **10** Inches To **250** Feet
 From **0** Feet To **250** Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 | 3.63 | .250 | 0 | 250 |

Perforations:
 Type perforation **SAWCUT**
 Size perforation **1/8 X 3**

| | | | | |
|------|-----|---------|-----|------|
| From | 160 | feet to | 250 | feet |
| From | | feet to | | feet |
| From | | feet to | | feet |
| From | | feet to | | feet |
| From | | feet to | | feet |

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **50** feet to **250** feet

9. WATER LEVEL
 Static water level **119** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.**
 Contractor

Address **P.O. BOX 4220** Contractor
PAHRUMP, NV. 89048 Contractor
 Nevada contractor's license number issued by the State Contractor's Board **47333**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1426**
 Signed *[Signature]*
 By driller performing actual drilling on-site or contractor
 Date **6/9/04**

Date started **5/10/2004**, 19
 Date completed **5/13/2004**, 19

7. WELL TEST DATA

| TEST METHOD: | Bailer | Pump | Air Lift |
|--------------|-------------------------------|--------------|----------|
| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) | |
| | | | |
| | | | |
| | | | |
| | | | |