WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

USE ADDITIONAL SHEETS IF NECESSARY
STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93343
Permit No.
Basin 162

NOTICE OF INTENT NO. 26508

1. OWNER BYRON & KAY MCCREA ANDERSON
MAILING ADDRESS 520 W. LEFFNER DR
PAHRUMP, NV

ADDRESS AT WELL LOCATION 520 W. LEFFNER DR.

2. LOCATION NE 1/4 NW 1/4 Sec. 28 T 19 N/S R 53 E NYE County
PERMIT NO. Issued by Water Resources
29-871-32 Parcel No.
BELL VISTA 3 Subdivision Name

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
SILT		0	15	15
CLAY		15	21	6
CALICHE		21	26	5
CLAY		26	75	49
CALICHE		75	80	5
CLAY		80	100	20
CALICHE	WB	100	115	15
SAND	WB	115	135	20
CALICHE	WB	135	140	5
CLAY		140	153	13
CALICHE	WB	153	165	12
CLAY		165	175	10
CALICHE	WB	175	180	5
GRAVEL PACK INSIDE				
CASING TO 135 FT.				
BECAUSE BOTTOM PART OF				
WELL MAKES ALOT OF				
SAND				

Date started 5/12/2004, 19__
Date completed 5/15/2004, 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRUCTION**
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	180	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	180

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 100 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 180 feet

9. **WATER LEVEL**
Static water level 72 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
Address P.O. BOX 4220 Contractor
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed By driller performing actual drilling on-site or contractor
Date 6/1/04