

23

Well #1 of 2

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 93348  
Permit No. \_\_\_\_\_  
Basin. 212

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26495

1. OWNER BRC ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS 875 W. Warm Springs Rd  
Henderson NV 89015  
2. LOCATION NE 1/4 NE 1/4 Sec 31 T 21 N R 63 E Clark County  
PERMIT NO. 1604501002 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other SONIC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy Gravel</u>		<u>0</u>	<u>25</u>	<u>25</u>
<u>Silty Clay</u>		<u>25</u>	<u>155</u>	<u>130</u>
<u>Silty Sand</u>		<u>155</u>	<u>205</u>	<u>50</u>
<u>Clayey silt</u>		<u>205</u>	<u>400</u>	<u>195</u>

8. WELL CONSTRUCTION  
Depth Drilled 400 Feet Depth Cased 205 Feet  
HOLE DIAMETER (BIT SIZE)  
From To  
8 1/2 Inches 0 Feet 400 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>	<u>Sch 80</u>	<u>PVC</u>	<u>0</u>	<u>195</u>

Perforations:  
Type perforation Slotted PVC  
Size perforation .010  
From 195 feet to 205 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 188  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 192 feet to 205 feet

9. WATER LEVEL  
Static water level \_\_\_\_\_ feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 4-30-04, 20 \_\_\_\_\_  
Date completed 5-3-04, 20 \_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Prosonic Corp Contractor  
Address 419 E Juniper #104 Contractor  
Mesa AZ 85204  
Nevada contractor's license number issued by the State Contractor's Board 0051765  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1941  
Signed Mike Winter  
By driller performing actual drilling on site or contractor  
Date 6-4-04