COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93343
Permit No.
Basin 105
NOTICE OF INTENT NO. 49746

1. OWNER JACK WHITE CUSTOM HOMES
MAILING ADDRESS 423 CLAIRE CT
GARDNERVILLE, NV 89410

ADDRESS AT WELL LOCATION 1112 CORTEZ LN
GARDNERVILLE, NV 89410

2. LOCATION ~~NE~~ SE ¼ ~~SW~~ NW ¼ Sec 12 T 12 N R 20 E DOUGLAS County
PERMIT NO. Issued by State Engineer
1220-12-610-010 Permit No.
PINION RIDGE ESTATES Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVER BURDEN		0	3	3
COBBLES AND SANDS		3	76	73
BROWN CLAY		76	148	72
COURSE SANDS AND CLAY SEAMS		148	210	62
BROWN CLAY		210	291	81
COURSE FRACTURED GRAVELS AND SAND	XXX	291	340	49

RECEIVED 04 JUN -8 AM 10:49 STATE ENGINEERS OFFICE

Date started 5/14, 20 04
Date completed 5/17, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	35	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 340' Feet Depth Cased 340' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	120 Feet
9 7/8 Inches	120 Feet	340 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	340

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 320 feet to 340 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 55 ☐ Neat Cement
Placement Method: ☐ Pumped ☒ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 55 feet to 340 feet

9. WATER LEVEL
Static water level 180 feet below land surface
Artesian flow G.P.M 30 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 5/24/04

(Rev 3-91) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429