

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 93364  
 Permit No. \_\_\_\_\_  
 Basin 105  
 NOTICE OF INTENT NO. 49747

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **GREG LYNN CONSTRUCTION**  
 MAILING ADDRESS 780 EMIGRANT TRAIL  
MARKLEEVILLE, CA 96120  
 ADDRESS AT WELL LOCATION 223 MOUNTAIN REACH CT  
GARDNERVILLE, NV 89410

2. LOCATION SW 1/4 SW 1/4 Sec 3 T 12 N R 19 E DOUGLAS County

PERMIT NO. 1219-03-002-009

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other **MUD**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DG SANDS AND LARGE BOULDERS		0	25	25
COURSE DG SANDS		25	83	58
FRACTURED DG BOULDERS		83	136	53
SANDY DG CLAY		136	182	46
DG SANDS		182	203	21
FRACTURED DG GRAVELS AND COBBLES	XXX	203	250	47

8. WELL CONSTRUCTION  
 Depth Drilled 250 Feet Depth Cased 250 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
10 5/8 Inches 0 Feet 250 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>250</u>

Perforations:  
 Type perforation FACTORY MILL SLOT  
 Size perforation 3 X 3/32  
 From 230 feet to 250 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 250 feet

9. WATER LEVEL  
 Static water level 120 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 25 P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name CAPITAL CITY WELL DRILLING  
 (CONTRACTOR)

Address 20 KIT KAT DRIVE  
 (CONTRACTOR)  
CARSON CITY, NV 89706  
 Nevada contractor's license number issued by the State Contractor's Board 00055548  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157

Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 6/4/04

Date started 5/11, 20 04  
 Date completed 5/13, 20 04

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>45</u>	<u>3 HRS</u>

RECEIVED  
 04 JUN -8 AM 10:49  
 STATE ENGINEERS OFFICE