

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 93356  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49745

1. OWNER MARCUS WERTZ  
 MAILING ADDRESS 3500 GREEN ACRE DR.  
CARSON CITY, NV 89705

ADDRESS AT WELL LOCATION 3500 GREWEN ACRE DR.  
CARSON CITY, NV 89705

2. LOCATION NW 1/4 SE 1/4 Sec 7 T 14 N R 20 E DOUGLAS County

PERMIT NO. \_\_\_\_\_  
 Issued by Water Resources Permit No. 1420-07-210-007

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
OVER BURDEN		0	3	3
DG SANDS HARDPAN		3	18	15
COURSE DG SANDS		18	76	58
BROWN DG CLAY		76	154	78
DG GRANITE				
RUSTY CLAY SEAMS		154	263	109
HARDER DG GRANITE		263	272	9
SOFTER DG SANDS		272	302	30
FRACTURED SOFTER DG SANDS	XXX	302	340	38

RECEIVED  
 04 MAY 24 AM 11:02  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION

Depth Drilled 340' Feet Depth Cased 340' Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
10 5/8 Inches 0 Feet 340 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	340

Perforations:  
 Type perforation FACTORY MILL SLOT  
 Size perforation 3 X 3/32  
 From 320 feet to 340 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 60  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 60 feet to 340 feet

9. WATER LEVEL

Static water level 185' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 15 P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CAPITAL CITY WELL DRILLING  
 (CONTRACTOR)

Address 20 KIT KAT DRIVE  
 (CONTRACTOR)  
CARSON CITY, NV 89706

Nevada contractor's license number issued by the State Contractor's Board 0055548

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157

Signed Rick Crase  
 By driller performing actual drilling on site or contractor

Date 5/5/04

Date started 4/26, 20 04  
 Date completed 4/28, 20 04

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>	<u>65</u>	<u>3 HRS</u>