



Log No. 93363  
 Permit No. \_\_\_\_\_  
 Basin 102

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 18580

PRINT OR TYPE ONLY

1. OWNER T. Tabba Corp. ADDRESS AT WELL LOCATION H775 LEMONY ST.  
 MAILING ADDRESS P.O. Box 323 Silver Springs, Nv. 89429  
 2. LOCATION SE 1/4 SE 1/4 Sec 31 T. 18 N/S R. 25 E LYON County  
 PERMIT NO. 17-053-06 Parcel No. Valley View #1 Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other  Replacement well  
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fine Brown Sand		0	20	20
Fine to coarse Brown Sand		20	45	25
Fine to coarse Gray Sand	X	45	120	75
Fine to coarse Gray Sand + Some Gray Clay	X	120	145	25
Brown Sand + Some Brown clay		145	180	35
Fine to coarse Gray Sand + Some Gray Clay		180	185	5
Fine to coarse Brown Sand + Some Brown Clay		185	205	20
MULTICOLORED coarse Sand	X	205	240	35

8. WELL CONSTRUCTION  
 Diameter 12 1/4 inches Total depth 240 feet  
 Casing record 8 5/8 O.D.  
 Weight per foot \_\_\_\_\_ Thickness 1.88  

Diameter	From	To
<u>8 5/8</u> inches	<u>+1</u> feet	<u>240</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type CEMENT  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 240 feet  
 Perforations:  
 Type perforation MILL  
 Size perforation 3/16 X 3  
 From 200 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 4-20, 1992  
 Date completed 4-25, 1992

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After, Hours Pump
<u>3200 240</u>	<u>45</u>	<u>27</u>	<u>2</u>
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL  
 Static water level 44 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Ace Drilling & Development Contractor  
 Address P.O. Box 668 Silver Springs Nv. 89429 Contractor  
 Nevada contractor's license number 14299 issued by the State Contractor's Board  
 Nevada contractor's driller's number 726 issued by the Division of Water Resources  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 726  
 Signed H.L. Holb By driller performing actual drilling on site or contractor  
 Date 4-27-1992

BAILER TEST  
 G.P.M. 18 Draw down 10 feet 2 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours