WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93375
Permit No.
Basin 87

NOTICE OF INTENT NO. 19306

1. OWNER William Manke
MAILING ADDRESS 2500 Longley Lane Reno Nevada
ADDRESS AT WELL LOCATION 8300 Clean Water Way Reno Nevada

2. LOCATION Portion NE ¼ Sec 15 T 19 N N/S R 20 E Washoe County
PERMIT NO. ____ Issued by Water Resources | Parcel No. 5 | Subdivision Name 021-020-08 ?

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brn Top Soil		0	8	8'
Gray sandy Clay		8	30	22'
gravel 1/4"		30	40	10'
gravel 1/2 inch		40	50	10'
gray sand		50	62	12'
gravel 1/4"		62	67	5
gray sand fine	✓	67	150	83
			T.D.	

'92 APR 27 P12:08
RECEIVED
STATE ENGINEERS OFFICE

Date started 4-17, 1992
Date completed 4-18, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	Blowing From 100 Ft.	5 hrs

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4 Inches	0 Feet	150 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7"	23#		0	140

Perforations:
Type perforation Factory slot
Size perforation 1/16"
From 100 feet to 140 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0 to 100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 140 feet

9. WATER LEVEL
Static water level 14 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature 62 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name San Emidio Resources Contractor
Address P.O. Box 40 Empire, Nev. 89405 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0018103 C-23
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1558
Signed Michael Clear
By driller performing actual drilling on site or contractor
Date 4-20-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627