

Well #1 of 2

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 93385
Permit No. _____
Basin. 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26039

1. OWNER BRC ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 875 W. Warm Springs Rd
Henderson NV 89015
2. LOCATION NW 1/4 NE 1/4 Sec 36 T 21 N R 62 E Clark County
PERMIT NO. 16136101002 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
5. WELL TYPE Cable Rotary RVC Air Other Special

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy Gravel</u>		<u>0</u>	<u>53</u>	<u>53</u>
<u>Clayey silt</u>		<u>53</u>	<u>64</u>	<u>9</u>
<u>Silty sand</u>		<u>64</u>	<u>92</u>	<u>28</u>
<u>Clayey silt</u>		<u>92</u>	<u>400</u>	<u>308</u>

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 137 Feet
HOLE DIAMETER (BIT SIZE)
8 3/4 Inches From 0 Feet To 400 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>	<u>5ch</u>	<u>50 PVC</u>	<u>0</u>	<u>107</u>

Perforations:
Type perforation slotted PVC
Size perforation .010
From 107 feet to 137 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
Depth of Seal 17
Placement Method: Pumped Poured
Gravel Packed: Yes No
From 107 feet to 137 feet

9. WATER LEVEL
Static water level 46 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

Date started 5-5-04, 20 ____
Date completed 5-8-04, 20 ____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Prosonic Corp Contractor
Address 419 E. Tropicita #104 Contractor
Mesa AZ 85204
Nevada contractor's license number issued by the State Contractor's Board 0051765
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1941
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 6-4-04