Well #1 of 2

16

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93395
Permit No.
Basin 212

NOTICE OF INTENT NO. 26048

1. OWNER BRC
MAILING ADDRESS 875 W Warm Springs Rd Henderson NV 85015
ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ NW ¼ Sec. 5 T. 22 N/S R. 63 E. Clark County
PERMIT NO. (Issued by Water Resources) 17905301004 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel		0	55	55
Silty Sand		55	70	15
Silty Clay		70	97	27
Silt		97	127	30
Clayey Silt		127	130	3
Silty Sand		130	156	26
Silty Clay		156	175	19
Sandy Silt		175	195	20
Silty Clay		195	219	24
Sandy silt		219	230	11
Clayey silt		230	254	24
Sandy silt		254	260	6
Silty Clay		260	297	37
Sandstone		297	299	2
Clayey Silt		299	320	21
Silty Sand		320	368	48

DCNR/DWR
RECEIVED
JUN 09 2004
LAS VEGAS OFFICE

Date started 5-10-04, 20
Date complated 5-13-04, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 368 Feet Depth Cased 314 Feet

HOLE DIAMETER (BIT SIZE)
8½ Inches From 0 Feet To 368 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	Sch	80 PVC	0	284

Perforations:
Type perforation Slotted PVC
Size perforation .010
From 284 feet to 314 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 225
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 281 feet to 314 feet

9. WATER LEVEL
Static water level 57.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Prosonic Corp (Contractor)
Address 419 E Juanita #104 (Contractor)
Mesa AZ 85204
Nevada contractor's license number issued by the State Contractor's Board 0051765
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1941
Signed [signature] By driller performing actual drilling on site or contractor
Date 6-4-04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627