WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93416
Permit No.
Basin 87

NOTICE OF INTENT NO. 49785

1. OWNER Truckee Meadows Water Authority
MAILING ADDRESS P.O. Box 30013
Reno, NV 89510

ADDRESS AT WELL LOCATION 6995 Lonley Lane Reno NV.

2. LOCATION SE ¼ SE ¼ Sec. 31 T. 19 N/S R. 20 E. Washoe County

PERMIT NO. W-567 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☑ Other water test

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☑ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravelly Sands Clay;		0	320	
Subrounded TO				
Angular gravels –				
Fine to medium				
Sands, Reddish –				
brown to tan				
plastic clays				
Gravelly Clay	32	44		
Gravelly Sand & Clay	44	58		
Sandy Clay to Sand	58	116		
Gravelly Clay to	116	158		
Gravelly Sand				
Clayey Sand	158	164		
Sand	164	176		
Gravelly Clay	176	188		
Gravelly Sand	188	198		
Gravelly Clay	198	222		
Gravelly Sand	222	230		
Silty Clay	230	238		
Sand	238	250		
Silty Clay	250	258		
Sand	258	264		
Silty Clay	264	280		
Sand	280	290		
Sand, Silty Clay	290	304		
Clay	304	310		
Casing Pulled Hole Reamed				
7yds Sand Slurry pumped bottom				
to Top				

Date started April 29, 2004, 20__
Date completed April 30, 2004, 20__

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5-14-04	200	8' Before Started	8:00-10:00-2
5-14-04	300		10:00-12:00-2
5-14-04	400		12:00-2:00-2
5-14-04	500	35'	2:00-4:00-2

8. WELL CONSTRUCTION
Depth Drilled 310 Feet Depth Cased 295 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 7/8 Inches		0 Feet	295' Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8			295	0

Perforations:
Type perforation 0.25" wall mild steel - .080 slot
Size perforation 6 5/8 O.D.
From 97 feet to 147 feet
From 158 feet to 198 feet
From 219 feet to 249 feet
From 260 feet to 270 feet
From 280 feet to 290 feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal 76-92 Bentonite, mechin chips
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 300' feet to 92 feet

9. WATER LEVEL
Static water level 8 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration (Contractor)
Address PO Box 141 Zamora CA. 95698 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0072852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2244
Signed Randy Crimes / By James Whitley (By driller performing actual drilling on site or contractor)
Date 6-7-04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627