WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93420
Permit No. 69314
Basin 230

NOTICE OF INTENT NO. 24541

1. OWNER Nye County
MAILING ADDRESS P.O. Box 153
Tonopah, NV. 89049

ADDRESS AT WELL LOCATION
Not assigned

2. LOCATION SE ¼ SE ¼ Sec. 18 T 15 S N/S R 50 E Nye County
PERMIT NO. 69314 (Issued by Water Resources) | 21-021-18 (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Volcanic sand & gravel		0	350	
w/ occasional cobble-				
stones				
White clay w/ sand		350	395	
& gravel				
Alternating layers of		395	785	
various thickness of				
cemented white sand				
and white clay w/ sand.				
Sandy clay w/ volcanic		785	1000	
sand, clay content				
gradually decreasing				

DCNR-DWR
RECEIVED
JUN 1 4 2004
LAS VEGAS OFFICE

Date started November 17, 20 03
Date completed May 28, 20 04

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Pumped	6	480	10

8. WELL CONSTRUCTION
Depth Drilled 1000 Feet Depth Cased 1000 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
24 Inches		0 Feet	50 Feet
18 Inches		50 Feet	1000 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
20			+1	50
10-3/4			+2	1000

Perforations:
Type perforation Wire wrap screen
Size perforation .050 slot
From 660 feet to 720 feet
From 920 feet to 980 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From Surface feet to 1000 feet

9. WATER LEVEL
Static water level 320 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thompson Drilling Co., Inc (Contractor)
Address 7227 Hauck St.
Las Vegas, NV. 89118 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0004286A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 290
Signed [signature] (By driller performing actual drilling on site or contractor)
Date June 8, 2004

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627