

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Wynn Design & Development ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3145 Las Vegas Blvd. S. 3131 Las Vegas Blvd. S.
Las Vegas, NV. Las Vegas, NV.

2. LOCATION SW $\frac{1}{4}$ NE $\frac{1}{4}$ Sec. 16 T. 21 S. N/S R. 61 E. Clark County
 PERMIT NO. 69515, 69516, 69517 162-16-113-001 N/A
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Recreational Irrigation Test
 Domestic Monitor Stock
 Municipal/Industrial

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy clay		0	75	
Sand w/ gravel		75	90	
Clay w/ silt & sand		90	110	
Cemented Sand		110	180	
Lt-Med. Brown Clay		180	210	
Sand & fine gravel		210	220	
Lt-Med. Brown Clay		220	280	
Clay w/ silt & sand		280	310	
Gravel w/ silty sand		310	330	
Gravel w/ sand		330	395	

8. WELL CONSTRUCTION
 Depth Drilled 395 Feet Depth Cased 395 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>30</u> Inches	<u>0</u> Feet	<u>50</u> Feet
<u>18-1/2</u> Inches	<u>50</u> Feet	<u>395</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12-3/4</u>		<u>.330</u>	<u>+2</u>	<u>272</u>
<u>12-3/4</u>		<u>.330</u>	<u>392</u>	<u>395</u>

Perforations:
 Type perforation Screen
 Size perforation .050

From	feet to
<u>272</u>	<u>392</u>
_____	_____
_____	_____
_____	_____
_____	_____

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50'

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From Surface feet to 395 feet

9. WATER LEVEL
 Static water level 117 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started March 6, 20 04
 Date completed May 28, 20 04

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Pumped</u>	<u>350</u>	<u>208</u>	<u>24 hrs.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Thompson Drilling Co., Inc. Contractor
 Address 7227 Hauck St. Contractor
Las Vegas, NV.

Nevada contractor's license number issued by the State Contractor's Board 0004286A
 Nevada driller's license number issued by the 290 Division of Water Resources, the on-site driller

Signed Richard K. Thompson
 By driller performing actual drilling on site of contractor
 Date June 8, 2004

DCNR/DWR
 RECEIVED
 JUN 03 2004
 LAS VEGAS OFFICE

