

**WELL DRILLERS REPORT**

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 1370

1. OWNER MIKE & JOYCE FISHER ADDRESS AT WELL LOCATION 1869 QUAIL  
 MAILING ADDRESS \_\_\_\_\_ CARSON CITY, NV.  
 \_\_\_\_\_ 89701  
 2. LOCATION SE  $\frac{1}{4}$  NE  $\frac{1}{4}$  Sec. 23 T. 15 N/S R. 20 E Orms by \_\_\_\_\_ County \_\_\_\_\_  
 PERMIT NO. 10-089-03 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden				
Volcanic Rock		0	94	94
Blue Granite		94	110	16
Volcanic Tuff, fractured		110	305	195
Tuff with multicolored Rock Chips	X	305	324	19
T. D. 324 Ft.				

8. WELL CONSTRUCTION  
 Diameter hole 8" inches Total depth 324 feet  
 Casing record 6 5/8" - .156  
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+18</u> feet	<u>324</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Grout  
 Depth of seal 60 feet  
 Gravel packed: Yes  No   
 Gravel packed from 60 feet to 324 feet

Perforations:  
 Type perforation Factory  
 Size perforation 3/32 X 3  
 From 303 feet to 324 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Flow 20+ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 70 °F. Quality good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name AQUA DRILLING & WELL SERVICE, INC.  
 Contractor  
 Address 2255 GLENDALE AVE. - SPARKS, NV. 89431  
 Contractor  
 Nevada contractor's license number 15291  
 Nevada contractor's drillers number 1132  
 Nevada driller's license number 1132  
 Actual Driller

Date started 4-22, 1983  
 Date completed 4-25, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well at 150 PSI at 600 CFM for 2 hrs. to clean and develop.			

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

Signed Roger M. Thrall Contractor  
 Date 4-25-83