COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93434
Permit No.
Basin 105
NOTICE OF INTENT NO. 49754

1. OWNER KURT JOHNSON DEVELOPMENT
MAILING ADDRESS P.O. BOX 1848
GARDNERVILLE, NV 89410

ADDRESS AT WELL LOCATION 1968 LACEY LANE
GARDNERVILLE, NV 89410

2. LOCATION SE ¼ SE ¼ Sec 24 T 12 N R 20 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) 1220-24-701-038 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
HARD PAN CLAY		0	5	5
BROWN CLAY		5	15	10
COURSE GRAVELS		15	78	63
BROWN CLAY	(DRY)	78	162	84
BROWN GUMMY CLAY		162	192	30
SMALL SILTY SANDS		192	213	21
SMSALL OBSIDIAN SANDS AND GRAVELS	XX	213	265	52

RECEIVED 04 JUN 25 AM 10:45 STATE ENGINEERS OFFICE

DCNR/DWR RECEIVED JUN 2 2004 LAS VEGAS OFFICE

Date started 5/27, 20 04
Date completed 5/29, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	40	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 265 Feet Depth Cased 265 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8	Inches	0 Feet	265 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	265

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 245 feet to 265 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 265 feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow G.P.M 30 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAY DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 6/14/04