


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 93440
 Permit No. _____
 Basin 89 88



NOTICE OF INTENT NO. **51685**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **Christine Routsis** ADDRESS AT WELL LOCATION **15792 Fawn Lane**
 MAILING ADDRESS **3000 Granite Pointe Dr.**
Reno, NV 89511

2. LOCATION SW 1/4 SW 1/4 Sec. 36 T 18N N/S R 19E E Washoe County
 PERMIT NO. 150-242-11 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown & Black Volcanic Rock		138	155	17
Red/Brown Volcanic Rock		155	163	8
Fracture	x	163	165	2
Brown Volcanic Rock		165	184	19
Fracture		184	186	2
Brown/Black Volcanic Rock	x	186	201	15
Fracture	x	201	208	7
Brown/Black Volcanic Rock	x	208	255	47
Fracture	x	255	264	9
Brown Volcanic Rock		264	277	13
Fracture	x	277	283	6
Brown Volcanic Rock		283	298	15

Washoe County Permit #W040095

RECEIVED
 04 JUN 21 PM 1:32
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 298 Feet Depth Cased 298 Feet

HOLE DIAMETER (BIT SIZE)
 From 6 1/8 Inches To 138 Feet
 From _____ Inches To _____ Feet
 From _____ Inches To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	10.79	.188	128	298

Perforations:
 Type perforation **Factory**
 Size perforation **3/32 x 3"**

From	188	feet to	208	feet
From	228	feet to	248	feet
From	268	feet to	288	feet
From		feet to		feet
From		feet to		feet

Surface Seal: Yes No
 Depth of Seal _____
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From ? feet to _____ feet

9. WATER LEVEL
 Static water level 123 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Bruce MacKay Pump & Well Service, Inc.** Contractor
 Address **1600 Mt. Rose Hwy** Contractor
Reno, NV 89511
 Nevada contractor's license number issued by the State Contractor's Board **23096**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **923**
 Signed *Bruce MacKay*
 By driller performing actual drilling off-site or contractor
 Date **6/8/04**

Date started 6/4/2004, 19
 Date completed 6/7/2004, 19

7. WELL TEST DATA

	TEST METHOD:			Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)		
Air	35+			2 hrs
Pump	15	1		2 Hrs