WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93441
Permit No.
Basin 101

NOTICE OF INTENT NO. 49566

1. OWNER Paul L. King
MAILING ADDRESS 4800 Voltaire St.
Carson City, NV 89703

ADDRESS AT WELL LOCATION 4400 Voltaire Street,
Carsaon City, NV. 89703

2. LOCATION NW 1/4 NE 1/4 Sec. 31 T 15N N/S R 20E E Carson City County
PERMIT NO. Issued by Water Resources | Parcel No. 9-253-09 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Removed 170' of 1-1/4" drop pipe with pump. Measured static water level at167.2 bgs. Measdured depth of well at 181'. Installed 4" bailer and bailed debris from well to a depth of 183', where we could no longer retreive any debris. Installed 6" Mills knife to a depth of 63' and perforated 4 rows per foot to surface. Remove Mills Knife and installed 178' of 2" tremme pipe. Mixed 41 bags of Portland Type II cement with approximately 200 gallons of water and pumped into well from bottom to surface. (no drillers log avbaliable)				

RECEIVED
04 JUN 21 AM 10:54
STATE ENGINEERS OFFICE

Date started 06/11/2004, 19__
Date completed 06/11/2004, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 183? Feet Depth Cased 183? Feet

HOLE DIAMETER (BIT SIZE)

		From	To
Inches	Feet	Feet	Feet
Inches	Feet	Feet	Feet
Inches	Feet	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		.188	surface	183'

Perforations:
Type perforation Mills Knife
Size perforation 1"x1/2"
From surface feet to 63' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 183'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 167.2' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Carson Pump Contractor
Address P.O. Box 20159 Contractor
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed Dan Trampe
By driller performing actual drilling on-site or contractor
Date 06/18/2004

USE ADDITIONAL SHEETS IF NECESSARY