WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93442
Permit No.
Basin 88

NOTICE OF INTENT NO. 54464

1. OWNER Wendy Peirce
MAILING ADDRESS 15992 Mt. Rose Hwy.
Reno, NV 89511

ADDRESS AT WELL LOCATION 15992 Mt. Rose Hwy.

2. LOCATION SE 1/4 SE 1/4 Sec. 34 T 18N N/S R 19E E Washoe County
PERMIT NO. _____ Issued by Water Resources
049-090-12 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other _____

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel	x	220	240	20
Volcanic rock gravel	x	240	280	40
Gray sand gravel				
boulders	x	280	315	35
Granite small				
fractures		315	335	20
Pee gravel gray rock	x	335	395	60
Brown clay mixed rock		395	397	2
Volcanic rock purple &				
red	x	397	420	23

Washoe county well permit # WL 040096

RECEIVED 04 JUN 21 PM 1:32 STATE ENGINEERS OFFICE

Date started 5/27/2004, 19__
Date completed 5/30/2004, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40+		4.5

8. WELL CONSTRUCTION
Depth Drilled 420 Feet Depth Cased 420 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	220	Feet	420	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	10.79	.188	210	420

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3

From	260	feet to	280	feet
From	300	feet to	320	feet
From	360	feet to	380	feet
From	400	feet to	420	feet
From		feet to		feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal _____
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 214 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2010
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 6/1/2004

USE ADDITIONAL SHEETS IF NECESSARY