WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93448
Permit No.
Basin 179

NOTICE OF INTENT NO. 52542

1. OWNER Robert & Jami Brinkerhoff
MAILING ADDRESS P.O. Box 1442
McGill, NV 89318

ADDRESS AT WELL LOCATION
2732N 48th West Street
Ely, NV 89301

2. LOCATION SW ¼ SW ¼ Sec. 15 T. 17N N/S R. 63 E. White Pine County

PERMIT NO. Domestic (Issued by Water Resources) | 61 (Parcel No.) | Cross Timbers (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil | | 0 | 5' | 5' |
| Hard Pan | | 5' | 10' | 5' |
| Water | 100' | | | |
| Gravel,Clay,Sand | | 10' | 204' | 194' |

RECEIVED
04 JUN 25 AM 10:37
STATE ENGINEERS OFFICE

DON'T OVER RECEIVED
JUN 2 [illegible]
LAS VEGAS OFFICE

Date started June 2, 2004
Date complated June 12, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | 12' | 2 hours |

8. WELL CONSTRUCTION
Depth Drilled 204 Feet Depth Cased 204 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10.5 Inches | 0 Feet | 204 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6.5 | | .188 | 0 | 204 |

Perforations:
Type perforation Mill Slot
Size perforation 1/8" x 3"
From 163 feet to 183 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55'
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 204 feet

9. WATER LEVEL
Static water level 85' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 52 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Shane Cooper (Contractor)
Address P.O. Box 151683, Ely, NV 89315 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0019112
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2251
Signed [signature] (By driller performing actual drilling on site or contractor)
Date June 16, 2004

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627