WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93466
Permit No.
Basin 162

NOTICE OF INTENT NO. 25973

1. OWNER Gonzales
MAILING ADDRESS 4140 W. Forest
Pahrump, NV 89048

ADDRESS AT WELL LOCATION 4140 W. Forest

2. LOCATION NE 1/4 NE 1/4 Sec. 26 T 20S N/S R 52E E Nye County
PERMIT NO. Issued by Water Resources | 28-592-08 Parcel No. | Vegas Acres Subdivision Name

3. **WORK PERFORMED**
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. **PROPOSED USE**
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. **WELL TYPE**
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
brown loam		0	3	3
grey loam		3	50	47
grey caleche	x	50	62	12
brown loam	x	62	92	30
grey loam	x	92	105	13
brown loam	x	105	142	37
grey loam	x	142	151	9
See next line	x	151	160	9
grey loam with caleche strings				

DCNR/DWR
RECEIVED
JUL 07 2004
LAS VEGAS OFFICE

Date started 6/1/04 , 19__
Date completed 6/1/04 , 19__

7. **WELL TEST DATA**
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRUCTION**
Depth Drilled 160 Feet Depth Cased 160+1 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	160	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	160

Perforations:
Type perforation sawcut
Size perforation .188
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 160 feet

9. **WATER LEVEL**
Static water level 58 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. (Contractor)
Address 5801 S. Homestead (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 6-27-04