

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24846

1. OWNER Becker Enterprises ADDRESS AT WELL LOCATION 901 W. Sunset Rd.  
 MAILING ADDRESS 50 S. Jones Blvd. Henderson, NV  
Las Vegas NV 89107  
 2. LOCATION NW 1/4 SE 1/4 Sec. 3 T. 22 N/S R. 62 E Clark County  
 PERMIT NO. 178-03-702-001 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Poorly graded sand with boulders		0'	7'	7
Poorly graded sand with gravel		7'	12.5'	5.5
Poorly graded sand with boulders		12.5'	17'	4.5
Poorly graded gravel with sand	17	17'	21'	4
Poorly graded sand with boulders		21'	22'	1
caliche		22'	28.5'	10.5
Poorly graded sand with gravel		28.5'	33'	4.5
Sandy lean clay with gravel		33'	39'	10

8. WELL CONSTRUCTION  
 Depth Drilled 39 Feet Depth Cased 39 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 39 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>PVC</u>	<u>Sch 40</u>	<u>0</u>	<u>39</u>

Perforations:  
 Type perforation Factory slot  
 Size perforation 020  
 From 14 feet to 39 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 12 to surface  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 12 feet to 39 feet

9. WATER LEVEL  
 Static water level 17' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started June 2, 2004  
 Date completed June 2, 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Elite Drilling Inc.  
 Address 5115 S. Industrial Rd. #104 Las Vegas, NV  
 Nevada contractor's license number issued by the State Contractor's Board 0054931  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-18169  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date 6-30-04