SWETTS

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93542
Permit No.
Basin 222

NOTICE OF INTENT NO. 26256

1. OWNER Peppermill Casinos Inc
MAILING ADDRESS 4600 Kietzke Lane
Reno, NV

ADDRESS AT WELL LOCATION
897 W Mesquite Blvd
Mesquite NV 89024

2. LOCATION SE ¼ NE ¼ Sec. 18 T. 13 N(S)R 71 E Clark County

PERMIT NO. _____ Issued by Water Resources | 001-18-602-005 Parcel No. | _____ Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Type II fill		00	20	20
Sandy silt		20	50.0	480

DONR/DWR
RECEIVED
JUN 24 2004
LAS VEGAS OFFICE

Date started 2-26, 2004
Date completed 3-1, 2004

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 50 Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 1/2 Inches	0.0 Feet	50.0 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.250		Sch 40 PVC	0.0	50.0
1.250		Sch 40 PVC	0.0	50.0

Perforations:
Type perforation Machine slotted .020 4.250 string
Type ~~Size~~ perforation Machine slotted .010 1 1/4 string
From 50.0 feet to 30.0 feet .020
From 50.0 feet to 30.0 feet .010
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 1'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 50.0 feet to 25.0 feet

9. WATER LEVEL
Static water level 47.0 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EAGLE DRILLING Contractor
Address 7150 Placid St Contractor
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2202
Signed [signature] By driller performing actual drilling on site or contractor
Date 3-11-04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627