

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26429

1. OWNER JOHN & PEGGY ELLENBURG ADDRESS AT WELL LOCATION GYPSON AV + SENECA ST. SANDY VALLEY NV.
 MAILING ADDRESS _____
 2. LOCATION NE 1/4 SE 1/4 1/4 Sec. 22 T. 24 N/S R. 56 E. CLACK County
 PERMIT NO. 200-22-801-007 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	6	6
CLAY		6	28	22
CALICHE		28	33	5
CLAY		33	57	24
CALICHE		57	62	5
CLAY + GRAVEL		62	92	30
CALICHE	W.B	92	102	10
CLAY + GRAVEL		102	112	10
BROWN SANDSTONE	W.B	112	140	28
FRACTURES				

DCNR/DWR
 RECEIVED
 JUL 15 2004
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>4.33</u>	<u>.316</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation SAW CUT
 Size perforation 8 INCH BY 6 INCH
 From 140 feet to 100 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50 FT.
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 140 feet to 50 feet

9. WATER LEVEL
 Static water level 8.8 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

Date started 6-10 2004
 Date completed 6-21 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BUDGET DRILLING CO Contractor
 Address P.O. Box 3505 PAHRUMP NV 89041 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 40020
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1523
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 6-28-2004