



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16299

1. OWNER CARICO FARMS INC. ADDRESS AT WELL LOCATION  
 MAILING ADDRESS P.O. BOX 18160 N 40° 3.639'  
RENO, NV. 89511 W 118° 29.602'

2. LOCATION SW 1/4 SW 1/4 Sec. 3 T. 25 N1/4R 31 E. PERSHING County  
 PERMIT NO. M/IO 13284 APR 07-451-08 Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SOFT, DARK GREY DRY CLAY</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>VERY SOFT, DAMP GREY CLAY</u>		<u>2</u>	<u>7</u>	<u>5</u>
<u>VERY SOFT, GREY BROWN, MOIST CLAY WITH SHELS</u>		<u>7</u>	<u>18</u>	<u>11</u>
<u>VERY LOOSE, GREENISH GREY WET CLAYRY SANDY SILT</u>		<u>18</u>	<u>26</u>	<u>8</u>

01111-6 110953

8. WELL CONSTRUCTION  
 Depth Drilled 26 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)  
 From 8 Inches 0 Feet 26 Feet  
 Inches..... Feet..... Feet  
 Inches..... Feet..... Feet

CASING SCHEDULE

Size O. D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2 3/8</u>	<u>SC40</u>	<u>.125</u>	<u>0</u>	<u>25</u>
	<u>PVC</u>			

Perforations:  
 Type perforation FACTORY SLOTS  
 Size perforation 20 T. HOWARDS  
 From 10 feet to 20 feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 8 FT  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No #8 SAND  
 From 8 feet to 25 feet

9. WATER LEVEL  
 Static water level 8 feet below land surface  
 Artesian flow..... G.P.M..... P.S.I.  
 Water temperature 60 °F Quality MURKY @ HYDROGEN SULPHIDE SMELL

Date started APRIL 30, 2004   
 Date completed APRIL 30, 2004

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>1 1/2</u>	<u>15</u>	<u>2 HRS.</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EARTH SCIENCE CONSULTANTS Contractor  
 Address 1242 GLENDALE AVE. Contractor  
SPARKS, NV. 89431

Nevada contractor's license number issued by the State Contractor's Board.....  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1621

Signed Tom Colona  
 By driller performing actual drilling on site or contractor  
 Date MAY 5, 2004