

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 93660
Permit No.
Basin 103
NOTICE OF INTENT NO 52012
3875 Rain Dance

1. OWNER **Robert Renteria**
MAILING ADDRESS **3875 Rain Dance**
Stage Couch, NV

ADDRESS AT WELL LOCATION

2. Location **SE 1/4 SE 1/4 Sec 27 T 18N R 23E**
PERMIT NO. **PARCEL NO. 015-041-45**

SUBDIVISION NAME **Lyon County**

3. WORK PERFORMED | 4. PROPOSED USE | 5. WELL TYPE
 New Well | Replace | Recondition | Domestic | Irrigation | Test | Cable | Rotary | RVC
 Deepen | Abandon | Other | Municipal/Industrial | Monitor | Stock | Air | Other | Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	15	15
Rock		15	200	200
Clay		200	350	150
Clay and Rock		350	625	275

Back filled with native material to 42'
Cement grout from 0 to 42'

8. WELL CONSTRUCTION
 Depth Drilled **625 feet** | Depth Cased **feet**
 HOLE DIAMETER (BIT SIZE)
 From To
11 inches 0 feet 60 feet
8 3/4 inches 60 feet 625 feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.94	188	0	0

Perforations:
 Type Perforation **Factory**
 Size perforation **3/32 x 3"**
 From feet to feet
 Surface Seal YES No Seal Type:
 Depth of Seal **42 feet** Neat Cement
 Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From feet to feet

9. WATER LEVEL
 Static water level **dry** feet below land surface
 Artesian flow **0 GPM 0 P.S.I.**
 Water Temperature **cold** Degrees F Quality

Date started **6-14-04**
Date completed **6-20-04**

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (hours)		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
 NV Contractors No. **14170**
 NV Driller's Lic (on site) **786**
 Signed *Stew McKay*
 By driller performing actual drilling on site or contractor
 Date **7-8-04**

RECEIVED
 04 AUG -4 AM 10:39
 STATE ENGINEERS OFFICE