WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93662
Permit No. 66427
Basin 103

PLUGGED WELL LOG 6088 PERMIT 19978
REDRILLED LOG# 93663

NOTICE OF INTENT NO. 52860

1. OWNER Reynen & Bardis
MAILING ADDRESS 1380 Greg St. #230 Sparks Nv. 89431
ADDRESS AT WELL LOCATION 351 Valley Vista Dr. Dayton NV.

2. LOCATION SW ¼ SW ¼ Sec. 33 T. 16 17 N/S R. 22 E. Lyon County
PERMIT NO. 66427 (Issued by Water Resources) 019-861-32 (Parcel No.) River Park (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Perforated Casing From 633 ft to 20 ft. Pumped 38½ yds of Neat Cement to Surface From Bottom up using Tremie pipe				

RECEIVED 04 AUG -2 AM 11:31 STATE ENGINEER'S OFFICE

Date started 6-7, 2004
Date complated 6-11, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 633 Feet Depth Cased 633 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
24 Inches	0 Feet	633 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	42.05	.250	0	633

Perforations:
Type perforation mill slot
Size perforation ¼"
From 200 feet to 633 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 20 ft
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 35 ft feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Zim Industries Inc (Contractor)
Address 4545 E. Lincoln (Contractor) Fresno Ca. 93725
Nevada contractor's license number issued by the State Contractor's Board 0037248
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2268
Signed Brad Meinzer (By driller performing actual drilling on site or contractor)
Date 7-26-04

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627