WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93663
Permit No. 66427
Basin 103

NOTICE OF INTENT NO. 51934

1. OWNER Reynen & Bardis
MAILING ADDRESS 1380 Greg St #230 Sparks Nv. 89431
ADDRESS AT WELL LOCATION 351 Valley Vista Dr. Dayton Nv.

2. LOCATION SW ¼ SW ¼ Sec. 33 T. 16 N/S R. 22 E/W Lyon County
PERMIT NO. 66427 Issued by Water Resources
019-861-32 Parcel No.
River Park Subdivision Name

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Reverse Rotary

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	50	
Sand		50	140	
Sand & gravel		140	160	
Clay		160	220	
Sandy clay		220	310	
SAND		310	360	
gravel, cobbles litteclay		360	460	
Clay sand some gravel		460	490	
Clayey sand		490	590	
Clay		590	620	

RECEIVED 04 AUG -2 AM 11:31 STATE ENGINEER'S OFFICE

Date started 6-8, 2004
Date completed 7-22, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Start Rate	1050	216	72

8. WELL CONSTRUCTION
Depth Drilled 620 Feet Depth Cased 610 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
42 Inches		0 Feet	40 Feet
26 Inches		40 Feet	620 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	42.05	.250	0	300
16	42.05	.250	360	400
16	42.05	.250	590	610

Perforations:
Type perforation SS wire wrap
Size perforation .070
From 300 feet to 350 feet
From 400 feet to 590 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100 ft
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 610 feet

9. WATER LEVEL
Static water level 57 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature 75 °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Zim Industries Inc. Contractor
Address 4545 E. Lincoln Contractor
Fresno Ca. 93725
Nevada contractor's license number issued by the State Contractor's Board 0037248
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2268
Signed Brad Meinzer By driller performing actual drilling on site or contractor
Date 7-26-04