WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 93686
Permit No.
Basin 88

NOTICE OF INTENT NO. 52192

1. OWNER Carol Eichmann
MAILING ADDRESS 5440 Wildwood Dr.
Reno, NV 89511

ADDRESS AT WELL LOCATION 5440 Wildwood Dr.

2. LOCATION NE 1/4 NW 1/4 Sec. 2 T 17N N/S R 19E E Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. 045-534-08 Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Coarse sand boulders | x | 142 | 175 | 33 |
| Boulders coarse sand & gravel | x | 175 | 315 | 140 |
| Brown coarse sand some fine sand | | 315 | 355 | 40 |
| Volcanic rock hard | x | 355 | 395 | 40 |
| Gray and brown sand | x | 395 | 455 | 60 |

Washoe County Well Permit # WL 040180

RECEIVED
04 JUL 28 AM 10:53
STATE ENGINEERS OFFICE

Date started 7/12/2004, 19__
Date completed 7/14/2004, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 75 | | 3 |

8. WELL CONSTRUCTION
Depth Drilled 455 Feet Depth Cased 455 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 6 1/8 | Inches | 142 | Feet | 455 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 5 | 10.79 | .188 | 130 | 455 |

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 395 feet to 455 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 132 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 7/16/2004

USE ADDITIONAL SHEETS IF NECESSARY