

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 93688
 Permit No. _____
 Basin 92A

NOTICE OF INTENT NO. **51682**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Craig Del Pointe ADDRESS AT WELL LOCATION 1250 Columbia Hill Rd.
 MAILING ADDRESS 1717 Marigold Ct. NV.
San Jose, CA 95133

2. LOCATION NE 1/4 NE 1/4 Sec. 36 T 22N N/S R 18E E Washoe County
 PERMIT NO. 79-342-16 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay		1	17	16
Granite sands		17	21	4
Brown sandy clay		21	46	25
Soft zone		46	47	1
Brown sandy clays		47	90	43
Gray sandy clay		90	110	20
Soft zone		110	112	2
Gray sandy clays		112	190	78
Soft zone	x	190	193	3
Gray sandy clay		193	204	11
Soft zone	x	204	219	15
Gray sandy clay		219	230	11
Soft zone	x	230	236	6
Gray sandy clay		236	254	18
Soft zone	x	254	269	15
Gray sandy clay		269	275	6

Washoe County Well Permit # WL 040158

RECEIVED
 04 JUL 15 AM 11:08
 STATE ENGINEERS OFFICE

Date started 7/8/2004 19
 Date completed 7/9/2004 19

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>21</u>		<u>3</u>

8. WELL CONSTRUCTION
 Depth Drilled 275 Feet Depth Cased 275 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>10 5/8</u>	<u>0</u>	<u>50</u>
<u>8 3/4</u>	<u>50</u>	<u>275</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+2</u>	<u>275</u>

Perforations:
 Type perforation Machine cut
 Size perforation 3/32 x 3

From 235 feet to 275 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50

Placement Method: Pumped Paired

Gravel Packed: Yes No
 From 50 feet to 275 feet

9. WATER LEVEL
 Static water level 90 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
 Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
 Nevada contractor's license number issued by the State Contractor's Board 23096
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed R. Bruce MacKay
 By driller performing actual drilling on-site or contractor
 Date 7/13/2004