



Log No. 936125
 Permit No. _____
 Basin. 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49122

1. OWNER Bob + Tina Wilson
 MAILING ADDRESS 1218 Ester Way
MINDEN NV 89423
 ADDRESS AT WELL LOCATION 1032 Stephanie Ln.
MINDEN NV 89423
 2. LOCATION SW 1/4 SW 1/4 Sec. 29 T. 14 S. R. 20 E. Douglas County
 PERMIT NO. 1420 29 401 003
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
soil, clay		0	6'	6
Pine med coarse SAND some clay layers	X	6	90	84
clay		90	105	15
med coarse SAND small gravel	X	105	140	35

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>STEEL</u>	<u>0.88</u>	<u>+2</u>	<u>4</u>
<u>6 5/8</u>	<u>PVC</u>	<u>SOR 17</u>	<u>4</u>	<u>104</u>

Perforations:
 Type perforation factory cut - SOR 21
 Size perforation 0.032
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From 104 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 140 feet

9. WATER LEVEL
 Static water level 6' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

Date started 5-8, 19____
 Date completed 5-11, 1904

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>250</u>		<u>2 hours</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Sierra Nv Drilling + Pump LLC
 Address 3540 Green Acres Dr
Carson City NV 89705
 Nevada contractor's license number 52078
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902
 Signed John B. Reich
 By driller performing actual drilling on site or contractor
 Date 6-25-04

RECEIVED
 04 JUL - 1 AM 8:23
 STATE ENGINEERS OFFICE