

OFFICE USE ONLY
 Log No. 93698
 Permit No. _____
 Basin 179

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51388

1. OWNER Brian & Joy Bennett ADDRESS AT WELL LOCATION Approximately 2 miles N.W. of Hercules Gap
 MAILING ADDRESS P.O. Box 151396
Ely, Nevada 89315

2. LOCATION NW 1/4 NW 1/4 Sec 8 T. 17 N. R. 63 E White Pine County
 PERMIT NO. P-7 APN 005-620-11 Smith Valley
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	2	2
Sand & Gravel		2	7	5
Clay		7	15	8
Sand & Gravel		15	30	15
Clay		30	35	5
Course Gravel & Clay		35	40	5
Cemented Sand & Gravel		40	70	30
Water Bearing Sand & Grav X		70	90	20
Course Gravel & Clay		90	100	10
Sand & Gravel with Clay Stringers	X	100	170	70
Brown Clay		170	180	10

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 180
11 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	180

Perforations:
 Type perforation Factory 6 Rows
 Size perforation 1/8" X 2 1/2"
 From 80 feet to 180 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 180 feet

9. WATER LEVEL
 Static water level 67 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Avenue Contractor
Ely, Nevada 89301
 Nevada contractor's license number 14790
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
 Signed Rich Lewis by Paul D. Christiansen
 By driller performing actual drilling on site or contractor
 Date July 13, 2004

Date started June 21 2004
 Date completed June 23 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>	<u>170</u>	<u>1-1/2</u>

RECEIVED
 04 JUL 19 PM 2:47
 STATE ENGINEERS OFFICE